




材料暨工程實驗室-台北



試驗報告

報告編號：HB-22-07332

C-22-31084

頁 數：1 OF 1

報告日期：111年10月14日

工程名稱：國產建材實業台北港大陸砂氯離子例行性檢驗
 委託單位：國產建材實業股份有限公司
 樣品名稱：大陸砂
 結構部位：砂石船邊取樣
 加註項目：金保順輪 V-2271(泉港)
 取樣人員：國產建材實業股份有限公司(楊昇儒)、國產建材實業股份有限公司購料部(張耀聰)
 送驗人員：國產建材實業股份有限公司(楊昇儒)
 會驗人員：NA
 取樣日期：111年09月18日
 收件日期：111年09月23日
 試驗日期：111年10月12日～111年10月14日

註：1. 以上資料(樣品名稱、送驗人員、會驗人員、試驗方法、試驗數量、收件日期及試驗日期除外)及下述報告內容標示#處係由顧客提供
 2. 除非另有說明，此報告結果僅對測試之樣品負責
 未經本公司事先書面同意，此報告不可部分複製
 3. 送樣方式為實驗室收件

試驗結果：

試驗項目	試驗方法	試驗結果
水溶性氯離子含量(%)	CNS 13407(2015)	0.002

註：本試驗報告之試驗地點同實驗室地址。

報告簽署人

本報告若有提供規範要求值時，該規範值僅供參考，合格之判定以委託單位實際要求為準。

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com.tw/Terms-and-Conditions> and, for electronic formal documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com.tw/Terms-and-Conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.

TWD 6130318

SGS Taiwan Ltd. | 35, Wu Chyuan Road, New Taipei Industrial Park, Wu Ku District, New Taipei City 248016, Taiwan / 248016 新北市五股區新北產業園區五權路35號
 台灣檢驗科技股份有限公司 | t (006-2) 2299-3279 | f (006-2) 2299-7057 | www.sgs.com.tw

Member of SGS Group