

試驗報告



報告編號：HB-23-03375

C-23-13859

頁數：1 OF 1

報告日期：112年05月24日

工程名稱：國產建材實業台北港大陸砂氯離子例行性檢驗
 委託單位：國產建材實業股份有限公司
 樣品名稱：大陸砂
 結構部位：砂石船邊取樣
 加註項目：源順輪 V-2320(青州)
 取樣人員：國產建材實業股份有限公司(楊昇儒)、國產建材實業股份有限公司-購料部(張耀聰)
 送驗人員：國產建材實業股份有限公司(楊昇儒)
 會驗人員：NA
 取樣日期：112年05月06日
 收件日期：112年05月08日
 試驗日期：112年05月11日 ~ 112年05月18日
 備註：1. 以上資料(送驗人員、會驗人員、試驗方法、試驗數量、收件日期及試驗日期除外)及下述報告內容標示#處係由顧客提供

2. 除非另有說明，此報告結果僅對測試之樣品負責
 未經本公司事先書面同意，此報告不可部分複製

3. 收件方式為實驗室收件；收件地點：新北市五股區(新北產業園區)五權路55號

試驗結果：

試驗項目	試驗方法	試驗結果
水溶性氯離子含量(%)	CNS 13407:2015	0.000

註：1. 樣品描述：細粒料

2. 本試驗報告之試驗地點同實驗室地址



本報告若有提供規範要求值時，該規範值僅供參考，合格之判定以委託單位實際要求為準。

報告簽署人

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at <http://www.sgs.com.tw/Terms-and-Conditions> and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at <http://www.sgs.com.tw/Terms-and-Conditions>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested.